

# R.O. DRINKING WATER SYSTEM

## MODEL HPW-5000



### Performance Data Sheet



Point-of-Entry System Certified by IAPMO R & T under NSF/ANSI 61 for Materials Safety requirements only.



Certified by IAPMO R & T and ASSE to LEC 2006 for the contaminants listed below.



This system has been evaluated by ASSE international for Halal compliance.

This Reverse Osmosis system contains replaceable treatment components critical for effective performance. It is the user's responsibility to heed all alerts and warning from the system concerning filter, calcite cartridge and element replacement from the on board display and the mobile app. The manufacturer also recommends that the user periodically test the product water to verify the system is performing correctly.

Genuine HPW replacement filters, cartridges, and elements must be used. Use of other components will invalidate all claims for health and performance. Use only HANS Premium Water Replacement treatment components: 7304 Sediment Filter, 7303 Carbon Filter, 7858 Chlorine Stage 2 Filter, 7953 Chloramines Stage 2 Filter, 7256 RO Membrane, and 7516 Calcite Filter.

See Owner's manual for complete installation/operation and maintenance requirements, as well as user responsibility and parts and service availability. See Owner's manual for Manufacture's limited warranty.

The Elements in this system have been tested for the reduction of performance claims on this Performance Data Sheet as verified and substantiated by a third party for Reverse Osmosis elements only.

Chlorine in the influent water may affect the R.O. membrane polymers.

This device is certified by IAPMO R&T for the specific contaminants outlined below, as verified and substantiated by test data.

This system has been tested and shown to operate at its calculated recovery rating and efficiency rating under standard test conditions.

Following EPA water regulations, this system keeps RO finished water within EPA Standards for pH. This system has a built-in calcite filter system, which helps stabilize pH levels and reduces the chance of corrosion to consumer's indoor plumbing.

This system has a built in monitor for live steam of total dissolved solids performance. The monitor compares the level of the TDS in the supply (feed) water versus the product water and calculates the percent rejection. The monitor is programed to indicate a level of 75% rejection. In the case a level of 75% rejection of TDS is not achieved, this system will send warning alerts to the built-in touch screen and to the customer's smart phone visa HANS app.

# HPW R.O. DRINKING WATER SYSTEM

## MODEL HPW-5000

**REDUCTION PERFORMANCE CLAIMS:** This system has been tested according to LEC 2006 for reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system, as specified in LEC 2006. While testing was performed under standard laboratory conditions, actual performance may vary. The IAPMO R&T certification is reviewed annually and retesting is performed every five years, or as needed as determined by the annual review.

Substances	Required Influent Challenge Concentration (mg/L)	Maximum Permissible product water concentration (mg/L)	Average % Reduction
Arsenic (Pentavalent)	0.05 ± 10%	0.010	94.43
Arsenic (Trivalent)	0.05 ± 10%	0.010	95.10
Barium (Radium 226/228)	10.0 ± 10% (25 pCi/l ± 10%)	2.0 (0.07)	94.26
Chloroform	0.3 ± 10%	0.015	98.26
Chromium (Hexavalent)	0.30 ± 10%	0.1	92.75
Fluoride	8.0 ± 10%	1.5	88.25
Hardness	300 ± 10%	75	97.17
Iron	3-5	0.3	98.70
Lead	0.15 ± 10%	0.005	99.35
Nitrate	27.0 ± 10%	10.0	94.59
Nitrite	3.0 ± 10%	1.0	85.42
PFOA and PFOS	0.0015 ± 20%	0.00007	96.32
TDS	750 ± 10%	150	92.29

This system has been tested for the treatment of water containing pentavalent arsenic [also known as As(V), As(+5), or arsenate] and trivalent arsenic [also known as As(III), As (+3), or arsenite] at concentrations of 0.050 mg/L or less. This system reduces pentavalent and trivalent arsenic, but may not remove other forms of arsenic. This system is to be used on water supplies containing a detectable free chlorine residual or on water supplies that have been demonstrated to contain only pentavalent and trivalent arsenic. Treatment with chloramine (combined chlorine) is not sufficient to ensure complete conversion of trivalent arsenic to pentavalent arsenic. Please see the Arsenic Facts section of the Performance Data Sheet for further information.

This system is acceptable for treatment of influent concentrations of no more than 27 mg/L nitrate and 3 mg/L nitrite in combination measured as N and is certified for nitrate/nitrite reduction only for water supplies with a pressure of 50 psi or greater.

For test purposes, barium shall be added to the influent challenge water and shall be analyzed in the influent challenge water and product water. The reduction of radium is not concentration-dependent; therefore, barium shall be added at 10 mg/L with a maximum product water level of 2.0 mg/L. Barium is used as a surrogate based on its relationship with radium on the periodic table and the difficulty in using radium for routine testing.

### APPLICATION GUIDELINES / SPECIFICATIONS AND FEATURES

#### Water Supply Parameters / Operating Limits

Max. Working Inlet Pressure	80 psig (550 kPa)
Max. Working Pressure after pump	200 psig (1370 kPa)
Min. Working Inlet Pressure	30 psig (206 kPa)
Min. /Max. temperature	32°-113° F (0°-45° C)
Max. Feed Water pH	9
Min. Feed Water pH	6
Max. T.D.S.	750 ppm
Max. Input Free Chlorine	4 ppm
Mas. Hardness	35 gpg
Max. Turbidity	1 NTU

#### System Rating / Parameters

Daily Production Capacity	5000 gallons
Rejection Rate (depending on influent water)	20-40%
Recovery Rating*	60-80%
Efficiency Rating*	60-80%
Storage Capacity	80 gallons
System Weight (Dry)	135 lb.
System Dimension (+ Storage tank)	48" x 31" x 62"

Do not use with water that is microbiologically unsafe or of known quality without adequate disinfection before or after the system.

This reverse osmosis system contains replaceable treatment components, critical for the effective reduction of total dissolved solids and that product water shall be tested periodically for pH, nitrate, nitrite, and arsenic.

- Recovery Rating means the percentage of the influent water to the membrane portion of the system that is available to the user as R/O treated water when the system is operated without a storage tank or when the storage tank is bypassed.
- Efficiency rating means the percentage of the influent water to the system that is available to the user as R/O treated water under operation conditions that approximated typical daily usage.
- Production values based on 77°F (25°C), 550 ppm municipal tap water at 75 psi inlet. The product water shall be tested regularly to verify that the system is performing properly. Testing can be accomplished by contacting the service company that installed your R/O system or an authorized dealer.

See Owner's Manual for filter replacement frequency instructions. Owner's Manual can be found at: <https://hanspremiumwater.com/> or the California State Water Resources Control Board's internet Web site at [www.waterboards.ca.gov](http://www.waterboards.ca.gov).

# ADDITIONAL STATE OF IOWA INFORMATION

## FOR IOWA USE ONLY

Seller Name: \_\_\_\_\_

Address: \_\_\_\_\_  
\_\_\_\_\_

Phone: \_\_\_\_\_

Seller Signature: \_\_\_\_\_

Customer Signature: \_\_\_\_\_

Date: \_\_\_\_\_

(Signatures required prior to sale only in Iowa and signed sheet to be retained by seller for two years.)

## Warning!

While this Reverse Osmosis system contains replaceable treatment components to raise pH, RO water can lower pH. As this can be corrosive to some plumbing materials, care should be taken to properly maintain your system. It is the user's responsibility to heed all alerts and warnings from the system concerning calcite cartridge from the on board display and the mobile app, as these replaceable treatment components are critical to proper system performance. The manufacture also recommends that the user periodically test the product water to verify the system is performing correctly.

## pH and TDS Facts Section

This system has a calcite filter system built in, which helps stabilize pH levels and reduces the chance of corrosion to consumer's indoor plumbing. This systems product water pH levels will be within local state and regional codes if the incoming (feed) water is within stated water supply parameters. National Primary Drinking Water Regulations (NPDWRs) requires a range of 6.5-8.5 pH for product water.

Following EPA water regulations, this system keeps RO finished water within EPA Standards for pH.

pH levels should be tested periodically and filters changed at proper intervals to ensure proper pH levels of output water.

LEC 2006 requires a 75% total dissolved solids rejection to pass the requirement of the standard.

This system has a built-in monitor for live steam of total dissolved solids performance. The monitor compares the level of the TDS in the supply (feed) water versus the product water and calculates the percent rejection. The monitor is programed to indicate a level of 75% rejection. In the case a level of 75% rejection of TDS is not achieved, this system will send warning alerts to the built-in touch screen and to the customer's smart phone visa HANS app.

## Arsenic Facts Section

Arsenic (As) is a naturally occurring contaminant found in many ground waters. It generally occurs in two forms (valences or oxidation states): pentavalent arsenic (also known as As(V), As(+5) or arsenate) and trivalent arsenic (also known as As(III), As(+3) or arsenite). In natural ground water, arsenic may exist as trivalent arsenic, pentavalent arsenic, or a combination of both. Although both forms of arsenic are potentially harmful to human health, trivalent arsenic is considered more harmful than pentavalent arsenic. More information about arsenic and its toxicity can be found on the U.S. Environmental Protection Agency website at [http://www.epa.gov/safe\\_water/arsenic.html](http://www.epa.gov/safe_water/arsenic.html).

This system reduces pentavalent and trivalent arsenic, but may not remove other forms of arsenic.

Trivalent arsenic is generally more difficult to remove from drinking water than pentavalent arsenic. Trivalent arsenic can be converted to pentavalent arsenic in the presence of an effective oxidant such as free chlorine. The arsenic in water containing detectable free chlorine or that has been treated with another effective oxidant will be in the pentavalent arsenic form. Treatment with chloramine (combined chlorine) is not sufficient to ensure complete conversion of trivalent arsenic to pentavalent arsenic.

Consumers using public water supplies can contact their utility to verify whether free chlorine treatment chemicals are being used. Private water supplies and waters that do not have detectable free chlorine residuals should be analyzed to determine the form(s) of arsenic present and the potential need for oxidation of trivalent arsenic to pentavalent arsenic.

Arsenic does not generally impart color, taste, or smell to water; therefore, it can only be detected by a chemical analytical test. Public water supplies are required to monitor treated water for total arsenic (trivalent arsenic plus pentavalent arsenic) and the results are available to the public from the utility. Consumers using private water sources will need to make arrangements for testing. A total arsenic test usually costs about \$15 – \$30 and it is recommended a certified laboratory conduct the test. Local health departments or environmental protection agencies can help provide consumers with a list of certified laboratories. Some laboratories may also be able to analyze specifically for (speciate) the two forms of arsenic present in a water sample if requested.

This treatment system was tested under laboratory conditions as defined in LEC 2006 and found to reduce 0.050 mg/L influent arsenic challenge concentration in the test water to less than 0.010 mg/L, under standard testing conditions. Actual performance of the system may vary depending on specific water quality conditions at the consumer's installation. Following installation of this system, the consumer should have the treated water tested for total arsenic to verify arsenic reduction is being achieved and the system is functioning properly.

The pentavalent arsenic removal component of this system must be replaced at the end of its useful life. Replacement component(s) can be purchased from the original source of this system (retailer or distributor), from other sources of this treatment system, or directly from the manufacturer. Refer to the installation and owner's manual of your water treatment device to obtain replacement frequency and ordering information.

## California Proposition 65 Warning

**WARNING:** This product contains chemicals known to the State of California to cause cancer and birth defects or other reproductive harm. For more information and questions, please refer to The Office of Environmental Health Hazard Assessment for California at: [oehha.ca.gov/proposition-65/about-proposition-65](http://oehha.ca.gov/proposition-65/about-proposition-65).

User's responsibility to check HANS website for latest PDS revision.

Manufactured by:  
S2 Equipment LLC, 26700 Haggerty Road, Farmington Hills, MI 48331  
833-333-HANS